

Certificate of Flame Resistance





Rose Brand is in business in New York, New York with headquarters in Secaucus, New Jersey, and additional offices in Sun Valley, California, and in Orlando, Florida.

The fabric or substrate described below meets the minimum requirements of flame resistance established by the following tests:

- NFPA 701, TM #1
- Calif. Title 19, test #1237-1, small scale
- CAN/ULC S-109, small + large flame tests

Made with non-combustible elements, this IFR fabric is inherently and permanently flame resistant for the life of the fabric, without the addition of flame retardant chemicals. This flame resistance will NOT wash out. Rose Brand, however, recommends annual testing of the fabric using the NFPA 705 Field Test Method for Textiles, as accumulations of airborne dust and oils may diminish the flame resistance of the fabric.

Owner/Purchaser Name TBD Purchaser PO# TBD **Purchaser Project/Event Name TBD Rose Brand SO# TBD Rose Brand SO Date** TBD

Fabric Used: XX yards of 59" Luxe Velvet



For Rose Brand Textile Fabrics **Customer Service Representative** **Special New York City Certificate Available Upon Request**